



LEVITON®

Applications Cookbook
VerifEye® Submetering Solutions

Version 11.0

FOR REFERENCE ONLY

VERIFEYE SUBMETERING SOLUTIONS COOKBOOK NOTES

Measurement & Verification - Data Collection

GENERAL NOTES

1. REFER TO INSTALLATION INSTRUCTIONS FOR DEVICE SPECIFIC TERMINATIONS.
2. REFER TO DEVICE DATA SHEETS FOR DEVICE SPECIFIC DATA TRANSFER TYPES.
3. INSTALL CURRENT TRANSFORMERS (CT), VOLTAGE SENSORS, AND OTHER REQUIRED HARDWARE ASSOCIATED WITH THE PROPER OPERATION OF THE METERING EQUIPMENT PER NEC AND BEST PRACTICES.
4. CURRENT TRANSFORMERS AND VOLTAGE SENSORS NOT SHOWN FOR CLARITY.
5. MAXIMUM CURRENT TRANSFORMER LEAD RUN LENGTH DETERMINED BY CT TYPE. REFERENCE CT DOCUMENTATION PRIOR TO LAYING OUT EQUIPMENT.
6. LEVITON RECOMMENDS THE FOLLOWING USE OF ISOLATED PULSE OUTPUTS:
 - A. TENANT BILLING
 - USE kWh (1000) OUTPUT IN MOST APPLICATIONS.
 - IF 15 MINUTE INTERVAL DEMAND DATA IS REQUIRED, USE 10 WATT-HOUR OUTPUT. FOR HIGH ENERGY APPLICATIONS, (METERS RATED 800A OR HIGHER), USE kWh PULSE OUTPUT.
 - B. ENERGY MONITORING
 - USE 10Wh PULSE OUTPUT FOR MOST APPLICATIONS. THIS WILL PROVIDE BETTER DATA RESOLUTION WHEN USING PULSE ACCUMULATIONS TO TRACK 15 MINUTE INTERVAL DEMAND.
 - FOR HIGH ENERGY APPLICATIONS, (METERS RATED 800A OR HIGHER), USE kWh PULSE OUTPUT.
7. AN ENERGY MONITOR HUB AND SERIES 4000/4100 METERS MAY BE ON THE SAME MODBUS RTU LOOP. ONE TYPE PER LOOP SHOWN FOR SIMPLICITY.
8. MAXIMUM NUMBER OF CONNECTED DEVICES ON A MODBUS RTU LOOP IS 32.
9. BACNET MS/TP AS IT RELATES TO METERS SHOWN. MEDIA CONVERSION AND TRANSPORT ARE PART OF FACILITY BAS/BMS SYSTEM, NOT SHOWN FOR CLARITY.
10. FACILITY ETHERNET MAY INCLUDE MEDIA CONVERSION BETWEEN DEVICES. UTP SHOWN FOR SIMPLICITY. INDUSTRY STANDARD DISTANCES APPLY.
11. MODBUS IP AND BACNET IP ARE TRANSPORTED VIA ETHERNET.
12. REFER TO SPECIFIC METER DATA SHEETS FOR POLARITY REQUIREMENTS OF PULSE OUTPUT WIRES.

WIRE RUNS BY SYMBOL



1. LINE: 15AMP, 120VAC, 2 WIRE PLUS GROUND, 60HZ DIRECT FROM SERVICE PANEL, DO NOT SWITCH.
2. (1) ETHERNET CABLE EQUAL TO BELDEN 2412, LABELED PER DRAWING. TERMINATIONS PER EIA/TIA 568B. PASS-THROUGH CONNECTORS PROHIBITED.
3. (1) MODBUS RTU CABLE EQUAL TO BELDEN 1120A, LABELED PER DRAWING. MAXIMUM LENGTH 1200M (3935 FT).
4. (1) BACNET MS/TP CABLE: EIA-485 COMPLIANT CABLE, WIRING IN COMPLIANCE WITH ANSI/ASHRAE 135-2004.
5. COMMUNICATION WIRE: EQUAL TO (2) #18-22 AWG THHN PER METER. MAXIMUM 200 FT.
6. CT WIRE HARNESS AS NOTED BY MANUFACTURER AND AS SCHEDULED. MAX RUN LENGTH PER CT DOCUMENTATION.
7. REFERENCE AND POWER CIRCUIT: (1) 3-PHASE, 4-WIRE, PLUS GROUND CIRCUIT AT THE METERED VOLTAGE. FEED FROM DEDICATED 15A 3-POLE BREAKER.
8. POWER WIRE: BY FACTORY.
9. COMMUNICATION WIRE: BY FACTORY

NOTES BY SYMBOL



1. CONFIGURE HIGH DENSITY PULSE MODULE TO ASSOCIATED DEVICE(S). MAXIMUM 23 METERS.
2. CONFIGURE METER TO ASSOCIATED LOADS. REFERENCE GENERAL NOTE 5 FOR RECOMMENDED USE AND PANEL SCHEDULES FOR MONITORED LOADS.
3. CONFIGURE ENERGY MONITORING HUB (EMH) OR ENERGY MONITORING HUB AS REQUIRED. THE EMH HAS EIGHT (8) ON BOARD PULSE INPUT CHANNELS. EMB HUB HAS NO PULSE INPUT CHANNELS.
4. POWER SUPPLY, CORD AND PLUG PROVIDED AS A COMPLETE ASSEMBLY.
5. CONFIGURE HUBLITE AS REQUIRED. HUBLITE HAS FOUR (4) ON-BOARD PULSE INPUT CHANNELS.
6. MANAGED ETHERNET SWITCH, 10/100/1000.
 - A. PROVIDE MINIMUM TWO (2) SPARE PORTS. ASSUME AT LEAST ONE (1) BILLING COMPUTER PER SWITCH IN CALCULATIONS.
 - B. SWITCH SHALL HAVE A LINK FEATURE.
 - C. MULTIPLE SWITCHES SHALL BE LINKED TOGETHER.
7. CONFIGURE MODHOPPERS AS REQUIRED. MODHOPPER HAS (2) ON BOARD PULSE INPUT CHANNELS.
8. CONFIGURE EMH+ AS REQUIRED.
9. CONFIGURE DCAP AS REQUIRED.
10. CONFIGURE WIRELESS METERING DATA TRANSCEIVER TO ASSOCIATED DEVICE(S). MAXIMUM 1 OR 2 DEVICES DEPENDANT ON MODEL.


SYMBOLS

-  CONNECTOR BODY – FEMALE [CABLE MT'G]
-  PLUG – MALE [CABLE MT'G]
-  CROSSING WIRES, NO CONNECTION
-  CONNECTED WIRES
-  SEPARATE WIRES AS PART OF A BUNDLE
-  RECEPTACLE – FEMALE [PANEL MT'G]
-  INLET – MALE [PANEL MT'G]
-  WIRE RUNS NOT BY LEVITON
-  REFERENCE TO NOTES. DOES NOT TRANSCEND DRAWINGS.


TABLE OF CONTENTS

PAGE	DESCRIPTION
4	Individual Mini Meter to High Density Pulse Module, Monitoring System
5	Mini Meter MMU to High Density Pulse Module, Monitoring System
6	Individual Mini Meter to Energy Monitoring Hub
7	Mini Meter MMU to Energy Monitoring Hub, Monitoring System
8	Individual Series 2500 Meters to High Density Pulse Module, Monitoring System
9	Series 2500 Meter to Energy Monitoring Hub, Monitoring System
10	Individual Series 2500 Meter to Modbus TCP/IP
11	Individual Series 6000/Series 7000, 3-Circuit Meter to Modbus TCP/IP & Individual Series 3500/Series 7000, 3-Circuit Meter to BACnet IP
12	Individual Series 4x00/ Series 7000, 3-Circuit Meter to Modbus RTU & Individual Series 4x00/Series 7000, 3-Circuit Meter to BACnet MS/TP
13	Series 8000 Meter - Modbus RTU Option, Series 8000 Meter - BACnet IP Option, & Series 8000 Meter - Modbus TCP/IP Option
14	Series 7000 Meter - Modbus RTU Option, Series 7000 Meter - BACnet MS/TP Option, Series 7000 Meter Modbus TC/IP Option, & Series 7000 Meter BACnet IP Option
15	Pulse Meters - System Backbone - Modbus RTU to Ethernet
16	BACnet MS/TP Meters - System Backbone - BACnet MS/TP
17	System Backbone - Energy Monitoring Hubs to Ethernet
18	Meters - System Backbone - Series 7000 Meter/Series 8000 Meter to Modbus TCP/IP
19	Meters - System Backbone - Series 7000 Meter/Series 8000 Meter with Energy Monitoring Hub to BACnet IP
20	Meters - System Backbone - Series 6000 Meter/Series 7000 Meter/Series 8000 Meter to Bacnet IP
21	Mini Meter Pulse Output to High Density Pulse Module, Modbus to ModHopper
22	Series 4x00/Series 7000, 3-Circuit Meter to ModHopper, Monitoring System
23	Series 8000 Meters to ModHopper, Monitoring System
24	Meters - System Backbone - ModHopper
25	Meters - System Backbone - ModHopper
26	Pulse Meters - Individual Mini Meters, Series 2500, Gas, Water to Energy Monitoring Hub
27	Individual Mini Meter, Gas, Water, Series 4x00, 7000, 8000 and Series 2500 with High Density Pulse Module to Energy Monitoring Hub, Monitoring System
28	Series 7000 Meters to ModHopper, Monitoring System
29	Wireless Metering Data Transceivers, DCAP, and Repeater
30	Individual Mini Meter to Single Pulse Metering Data Transceiver (MDT) & Water and Gas Meter to Dual Pulse Metering Data Transceiver (MDT) & Individual Series 2500 Meter to Single Pulse Metering Data Transceiver (MDT)



INDIVIDUAL MINI METER TO HIGH DENSITY PULSE MODULE, MONITORING SYSTEM





MINI METER MMU TO HIGH DENSITY PULSE MODULE, MONITORING SYSTEM




INDIVIDUAL MINI METER TO ENERGY MONITORING HUB, MONITORING SYSTEM





MINI METER MMU TO ENERGY MONITORING HUB, MONITORING SYSTEM




INDIVIDUAL SERIES 2500 METERS TO HIGH DENSITY PULSE MODULE, MONITORING SYSTEM




SERIES 2500 METER TO ENERGY MONITORING HUB, MONITORING SYSTEM




INDIVIDUAL SERIES 2500 METER TO MODBUS TCP/IP




INDIVIDUAL SERIES 6000/SERIES 7000, 3 CIRCUIT METER TO MODBUS TCP/IP




INDIVIDUAL SERIES 6000/SERIES 7000, 3-CIRCUIT METER TO BACNET IP




INDIVIDUAL SERIES 4x00/SERIES 7000, 3-CIRCUIT METER TO MODBUS RTU




INDIVIDUAL SERIES 4x00/SERIES 7000, 3-CIRCUIT METER TO BACNET MS/TP




SERIES 8000 METER — MODBUS RTU OPTION




SERIES 8000 METER — BACNET IP OPTION



SERIES 8000 METER — MODBUS TCP/IP OPTION



SERIES 7000 METER - MODBUS RTU OPTION




SERIES 7000 METER LIMIT PER MODBUS (RS485) CIRCUIT:


1. 48 CIRCUIT
 - 71D48 - LIMIT 4
 - 73D48 (VIRTUAL ELEMENT) - LIMIT 30
2. 24 CIRCUIT - LIMIT 8
3. 12 CIRCUIT - LIMIT 16
4. 3 CIRCUIT - LIMIT 30
5. CONSULT FACTORY FOR ADDITIONAL DESIGN INFORMATION.

LINE (BLK)
NEU (WHT)
CIRCUIT 1
LINE FEED
(120V)


SERIES 7000 METER - BACNET/MSTP OPTION




SERIES 7000 METER - MODBUS TC/IP OPTION




SERIES 7000 METER - BACNET IP OPTION



PULSE METERS - SYSTEM BACKBONE - MODBUS RTU TO ETHERNET




BACNET MS/TP METERS - SYSTEM BACKBONE - BACNET MS/TP



SERIES 7000 METER LIMIT PER MODBUS (RS485) CIRCUIT:

1. 48 CIRCUIT
 - 71D48 – LIMIT 4 PER EMH MODBUS CHANNEL
 - 73D48 – LIMIT 30
2. 24 CIRCUIT – LIMIT 8
3. 12 CIRCUIT – LIMIT 16
4. 3 CIRCUIT – LIMIT 30
5. CONSULT FACTORY FOR ADDITIONAL DESIGN INFORMATION.


SYSTEM BACKBONE - ENERGY MONITORING HUBS TO ETHERNET



LEVITON®



**METERS - SYSTEM BACKBONE - SERIES 7000 METER/SERIES 8000 METER WITH
ENERGY MONITORING HUB TO BACNET IP**




The diagram illustrates a building layout with two main sections, 'A' and 'C', each containing three risers. Each riser is associated with a box labeled 'SERIES 6000 / 8000 / 7000 METER' and a circled number '2'. The risers are connected to a common vertical stack of ENx valves, which are also labeled with a circled number '2'.

BUILDING "A"


- RISER 3**: Connected to the top ENx valve.
- RISER 2**: Connected to the middle ENx valve.
- RISER 1**: Connected to the bottom ENx valve.

BUILDING "C"


- RISER 1**: Connected to the top ENx valve.
- RISER 2**: Connected to the middle ENx valve.
- RISER 3**: Connected to the bottom ENx valve.




MINI METER PULSE OUTPUT TO HIGH DENSITY PULSE MODULE, MODBUS TO MODHOPPER




MINI METER TO MODHOPPER ONBOARD PULSE INPUT TERMINALS




SERIES 4x00/SERIES 7000, 3 CIRCUIT METER PULSE OUTPUT TO MODHOPPER




SERIES 8000 METERS TO MODHOPPER, MONITORING SYSTEM




METERS — SYSTEM BACKBONE — MODHOPPER — MONITORING SYSTEM




METERS — SYSTEM BACKBONE — MODHOPPER




PULSE METERS—INDIVIDUAL MINI METERS, SERIES 2500, GAS, WATER TO ENERGY MONITORING HUB



INDIVIDUAL MINI METER, GAS, WATER, 4x00, 7000, 8000 AND SERIES 2500 WITH HIGH DENSITY PULSE MODULE TO ENERGY MONITORING HUB, MONITORING SYSTEM




SERIES 7000 METERS TO MODHOPPER, MONITORING SYSTEM






SERIES 7000 METER LIMIT PER MODBUS (RS485) CIRCUIT:

1. 48 CIRCUIT
 - 71D48 – LIMIT 4 PER VIRTUAL ELEMENT
 - 73D48 – LIMIT 30
2. 24 CIRCUIT – LIMIT 8
3. 12 CIRCUIT – LIMIT 16
4. 3 CIRCUIT – LIMIT 30
5. CONSULT FACTORY FOR ADDITIONAL DESIGN INFORMATION.

WIRELESS METERING DATA TRANSCEIVERS, DCAP, AND REPEATER



INDIVIDUAL MINI METER TO SINGLE PULSE METERING DATA TRANSCEIVER (MTD), WATER AND GAS METER TO DUAL PULSE METERING DATA TRANSCEIVER (MTD), INDIVIDUAL SERIES 2500 METER TO SINGLE PULSE METERING DATA TRANSCEIVER (MTD)



NOTE: PLEASE REFER TO SPECIFIC DATA SHEETS FOR POLARITY REQUIREMENTS FOR PULSE OUTPUT WIRING.



Leviton Manufacturing Co., Inc. Lighting & Controls

10385 SW Avery Street, Tualatin, OR 97062 **tel** 800-736-6682 **tech line** (6:00AM-4:00PM PT Mon-Fri) 800-959-6004

Leviton Manufacturing Co., Inc. Global Headquarters

201 North Service Road, Melville, NY 11747-3138 **tel** 800-323-8920 **tech line** (8:00AM-10:00PM ET Mon-Fri, 9:00AM-7:00PM ET Sat, 9:00AM-5:00PM ET Sun) 800-824-3005

Visit our website at: www.leviton.com/verifeye

©2025 Leviton Manufacturing Co. Inc. All rights reserved. Subject to change without notice.

G-8978K/L25-cds
REV DEC 2025