



Representative Image

Catalog No. U045F

Description: MIDWEST 60/30A HEAT PUMP F SWITCH N3R

UPC No 784567561708

Home > AC Disconnects > Heat Pump Disconnects

Multiple disconnect devices are offered for heat pump applications that require individual disconnects for the heating and cooling cycles. All pullers are removable or reinstallable in the OFF position for user safety during equipment maintenance. Their UL listing includes the ability to field replace the 60 Ampere puller in the left fuse block with a 30 Ampere puller (FH35-2) for installation flexibility but prohibits the interchangeability of pullers between fuse blocks to insure the proper fuse/puller combination is always reinstalled into the proper fuse block.

Descriptors

Category	Heat Pump Disconnects
----------	-----------------------

Specifications

Phase	1
Amps	90 A
Enclosure	Metallic
Circuit Protection	Fused Pull-Out
Receptacles	None
AIC	10,000
Cabinet Size	9 X 17
Horse Power Rating	10
Neutral Bar	NU100B2
Unit Weight	13.5 lb
Volts	120/240

Classifications

Standard Package	1
Stock Class Code	Stock

Approvals

Certification	UL/CUL
---------------	--------