







SUPPLIED WITH ACPL -
CLOSING PLATE (FOR
UNDERGROUND SERVICE),
ORDER TYPE A-L HUB
SEPARATELY (FOR
OVERHEAD SERVICE)



TENANT SERVICE DISCONNECTS (ORDER ONE PER SOCKET POSITION)			
TENANT CIRCUIT BREAKER CATALOG DESIGNATION (2-POLE)	CURRENT RATING AMPERES MIN – MAX	SHORT CIRCUIT BREAKER RATING RMS SYMMETRICAL AMPERES MAX ▲	VOLTS MAX
QBP-TM	70 – 200	10,000	240
QDP-TM	70 – 200	25,000	
QGP-TM	70 – 200	65,000	
QAP-TM	70 – 200	100,000	

KNOCKOUTS				
SYMBOL	CONDUIT SIZE		HOLE DIAMETER	
	IN	MM	IN	MM
A	.50	13	.88	22
B	.75	19	1.25	32
C	1.00	25	1.38	35
D	1.25	32	1.75	44
E	1.50	38	2.00	51
F	2.00	51	2.50	64
G	2.50	64	3.00	76
H	3.00	76	3.63	92
I	3.50	89	4.13	105
J	4.00	102	4.63	118



MOUNTING FOOT

RINGLESS COVER LATCH

- NOTES:
- FINISH – UL COMPONENT RECOGNIZED GRAY BAKED POWDER COAT PAINT OVER GALVANNEALED STEEL.
 - UL LISTED – FILE E-6294, SUITABLE ONLY FOR USE AS SERVICE EQUIPMENT. SUITABLE FOR OH/UG SERVICE.
 - LOAD PHASE LUGS ARE SUPPLIED AS A PART OF THE CIRCUIT BREAKER (TENANT SERVICE DISCONNECT).
 - ▲ SHORT CIRCUIT CURRENT RATING OF METER CENTER IS EQUAL TO THE RATING OF THE LOWEST INSTALLED TENANT SERVICE DISCONNECT.

				120/240VAC, 1ø3W DR 120/208 VAC, 1ø3W (DERIVED FROM A 208Y/120 VAC, 3ø4W NETWORK) (5TH JAW REQUIRED)		LOAD LUG WIRE SIZES (AWG-KCML)			
METER SDCKET COVER	NO. OF METER SCKETS	NO. OF JAWS	FACTORY INSTALLED BYPASS	MAIN BUS RATING	CATALDG NUMBER	LINE LUG WIRE SIZED (AWG/KCML)	PHASE 	NEUTRAL, SERVICE GROUND & CONVENIENCE EQUIPMENT GROUND	EQUIPMENT GROUNDING
						PHASE AND NEUTRAL			
RING-TYPE	5	4	NONE	800	MPC85200	SEE CIRCUIT BREAKER WIRE SIZE			2/0-14 CU 2/0-12 AL
RING-TYPE	6	4	NONE	800	MPC86200				
RINGLESS	5	5	NONE	800	MPC85200				
RINGLESS	6	5	NONE	800	MPC86200				
RINGLESS	5	5	HORN	800	MPC85200				
RINGLESS	6	5	HORN	800	MPC86200				

MECHANICAL LUGS FACTORY INSTALLED, LUG LANDING PADS AVAILABLE.
 ‡ LUGS LARGER THAN 600 KCML REQUIRE USE OF LUG LANDING PADS (ORDER CATALOG NUMBER MMSK2 SEPARATELY).
 THIS SERVICE APPLIES TO A LIMITED LIST OF REQUIREMENTS FOR GEOMETRIC DISCOUNT QUALIFICATION.

